

MIAMI-DADE FIRE RESCUE DEPARTMENT - INSPECTION REPORT



FIRE PREVENTION DIVISION
9300 NW 41 STREET, DORAL, FLORIDA 33178
PHONE 786.331.4800 FAX 786.331.4801



PERMIT # 00121-00264

Business Address: (District 8)
 DCPS KELSEY PHARR ELEMENTARY SCHOOL
 2000-2000 NW 46 ST
 MIAMI, FL 33142

Billing Address:
 DADE COUNTY PUBLIC SCHOOLS - DCPS
 1450 NE 2ND AVE ROOM 602
 MIAMI, FL 33132

RESULT: Immediate Final N.O.V
Resulted Date: 7/25/18

Permit Type: Education / Public Licensed Educ. Facility.
Inspection Month: September

Inspector:
 DAVID MCMILLON
 (786) 331-4852
 dmsmil@miamidade.gov

Code Enforcement Officer:
 JOSE GARCIA
 (786) 331-4806
 jose.garcia@miamidade.gov

NOTICE OF VIOLATION AND ORDER TO CORRECT

The hazards noted herein are in violation of the Florida Fire Prevention Code and/or Miami-Dade County Code and are deemed to be threats to life safety and/or property. You are hereby ordered to comply with the corrective measures prescribed. Nothing in this report supersedes any previously written, still existing violations for this occupancy.

APEALS

Any person who believes they were incorrectly issued a notice of violation or that the violation cited is not applicable to their occupancy classification or believes aggrieved by any action or decision of this code may appeal to the Miami- Dade County Fire Prevention and Safety Appeals Board by filing a written notice **within 30 days** of receiving the Notice of Violation and Order to Correct. The appeal request must be submitted in writing to the Secretary of the Board. Information on filing an appeal can be obtained on the web at: <http://www.miamidade.gov/fire/request-appeal.asp>. Filing of a written notice of appeal shall not stay the effect of any such action or decision which is the subject to the appeal. Section 14-36, Code of Miami-Dade County

Please Note: A Life Safety Permit required by Section 14-39, Code of Miami-Dade County, to operate the above named occupancy will be issued upon correction of all outstanding violations and payment of fees assessed. **Failure to obtain the required Life Safety Permit will result in enforcement actions including fines, citations, liens and/or orders to cease and desist operation.**

Viol.	Date Created	Comply by Date	Violation, Correction & Comments
1	8/17/17	9/16/17	<p style="text-align: center; color: red;">Failure to comply with below violations will result in issuance of a citation</p> <p>Violation: FFPC 6th Edition, NFPA 101:. 7.2.1.15.8 Door openings not in proper operating condition shall be repaired or replaced without delay..</p> <p>Correction: Repair or replace door openings to provide/maintain proper operating condition without delay..</p> <p>Comments: IE: ROOMS 1D & 1B..</p>
	Violation Corrected on 07/25/2018		
2	7/25/18	8/24/18	<p>Violation: FFPC 6th Edition, NFPA 101. 7.9.2.7 Emergency Lighting. Failure to maintain emergency lighting in working order..</p> <p>Correction: Repair emergency lighting to working condition. The emergency lighting system shall be either continuously in operation or shall be capable of repeated automatic operation without manual intervention..</p> <p>Comments: EMERGENCY LIGHTS JUST OPPOSITE THE PRINCIPAL'S OFFICE & INSIDE THE COPY ROOM DID NOT WORK DURING TESTING. (204).</p>




We would like feedback on your experience with your Life Safety Inspection .
 Please take a minute to complete our survey at:
http://bit.ly/mdfr_2tcSXHm

MIAMI-DADE FIRE RESCUE DEPARTMENT - INSPECTION REPORT

3	7/25/18	8/24/18	<p>Violation: FFPC 6th Edition, NFPA 1: 13.7.1.4.2 Fire Alarm Integrity Failure to maintain fire alarm system..</p> <p>Correction: Have a fire alarm contractor perform all required inspections, tests, and repairs in accordance with NFPA 70 and NFPA 72; provide report clear of deficiencies or impairments; provide documentation of correction of any deficiencies or impairments listed therein..</p> <p>Comments: HORN/STROBE OF THE FIRE ALARM SYSTEM IS HANGING LOOSE INSIDE THE BOYS STUDENT REST ROOM 1ST FLOOR. (411).</p>
---	---------	---------	---

CUSTOMER SIGNATURE

Title: Principal
Name: CAROL SIMPSON C/O LYNN FINCH-REGISTAR



Please Note: A life safety permit will be issued upon compliance of outstanding violations and payment of fees assessed. One (1) re-inspection will be performed at no additional cost. All subsequent re-inspections will be billed at one-half the original permit fee amount.



We would like feedback on your experience with your Life Safety Inspection .
Please take a minute to complete our survey at:
http://bit.ly/mdfr_2tcSXHm